

**Environmental  
Protection Agency**

John R. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott J. Nally, **Director**



October 3, 2011

RE: **NOTICE OF VIOLATION**  
**SUMMIT COUNTY**  
**COMMUNITY WATER SYSTEM**

**GREENTREE PLACE #4888**  
**PWS ID # OH7707812; STU ID #7758654**

**GREENTREE PLACE #4900**  
**PWS ID # OH7707912; STU ID #7758655**

**CERTIFIED MAIL**

Ms. Jean Hobbs  
Greentree Place Apartments  
P.O. Box 157  
Green, OH 44232

Dear Ms. Hobbs:

This letter is notification that the above referenced public water systems are in violation of Ohio Administrative Code (OAC) Rule 3745-83-01(G) for failure to monitor both the free and combined chlorine at least once every day that water is available to the public from the entry point (plant tap) to the distribution system.

The above referenced public water systems are also in violation of OAC Rule 3745-83-01(I)(2) for failure to have reports signed by the Operator in Responsible Charge and for failing to have reports submitted to the North East District Office no later than the tenth of the month following the month for which the reports were due.

The violations of the OAC are based upon information submitted by the Greentree Place #4888 and #4900 PWSs as reported on Monthly Operating Reports (MOR) #5002 for August 2011.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

J. Robert Henn  
Environmental Specialist  
Division of Drinking and Ground Waters

JRH/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Dave Bornino, Ohio EPA, Central Office, DDAGW  
Kenneth Baughman, Ohio EPA, Central Office, DDAGW  
Stivo DiFranco, Ohio EPA, NEDO, DDAGW Supervisor  
Kim Etters, Ohio EPA, NEDO, DDAGW