

**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



* 0 H 8 5 5 3 9 1 2 5 2 2 0 1 1 N O V *

September 2, 2011

RE: WAYNE COUNTY
MCDONALD'S RESTAURANT - WOOSTER
NON-TRANSIENT, NON-COMMUNITY PUBLIC
WATER SYSTEM
PWS ID # OH8553912
STU ID # 8559762

Ms. Teresa Dulemba
McDonald's Restaurant
2130 E. Lincoln Way
Wooster, Ohio 44691

Dear Ms. Dulemba:

On August 10, 2011, this office received the July 2011 Monthly Operating Report (MOR form 5002) from McDonald's Restaurant - Wooster. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since McDonald's Restaurant - Wooster treats its water by softening (hardness removal) and chlorine injection (disinfection), you are required to conduct monitoring for hardness and chlorine residual.

Please note the following violations:

- Ohio Administrative Code (OAC) 3745-83-01(G)(8)(a) requires a public water system serving fewer than two hundred and fifty persons that provide ion exchange treatment or membrane technology to reduce hardness shall monitor for hardness at least monthly at each entry point to the distribution system using a state certified laboratory. Since you are providing water softening, a monthly hardness sample is required to be collected, analyzed, and reported on the MOR.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Kristi Carathers, McDonald's Restaurant
Wayne County Health Department
Ohio EPA, Central Office, DDAGW