

**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



September 2, 2011

RE: WAYNE COUNTY
CHRISTIAN CHILDREN'S HOME
COMMUNITY WATER SYSTEM
PWS ID # OH8504912
STU ID # 8559626

Mr. Gary Porter, Executive Director
Christian Children's Home of Ohio
2685 Armstrong Rd.
Wooster, OH 44691

Dear Mr. Porter:

On August 10, 2011, this office received the July 2011 Monthly Operating Report (MOR form 5002) from Christian Children's Home PWS. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Little Christian Children's Home treats its water by chlorination (disinfection), you are required to conduct monitoring for chlorine residual.

Please note the following violation:

- Ohio Administrative Code (OAC) Section 3745-83-01 requires all community and major non-community water systems to maintain a minimum chlorine residual of at least 0.2 mg/L free chlorine, or 1.0 mg/L combined chlorine, measured at representative points throughout the distribution system. On 7 of 31 days during the month of January 2011, chlorine residuals were reported as less than 0.2 mg/L free chlorine, or 1.0 mg/L combined chlorine.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

Beth R. Madis, Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Tim Becker, Christian Children's Home of Ohio
Wayne County Health Department
Ohio EPA, Central Office, DDAGW