

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Naliy, Director



June 8, 2011

RE: WAYNE COUNTY
GAS & OIL, DOYLESTOWN, OH
TNC WATER SYSTEM
PWS ID# OH8557412

CERTIFIED MAIL

Mr. Anawa Singh
Veen Corp
18575 Edwards Road
Doylestown, OH 44230

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

Dear Mr. Singh:

This letter is notification that the Gas & Oil public water system has not complied with requirements issued during this Agency's last survey performed on January 5, 2011, in violation of rule 3745-81-60 of the Ohio Administrative Code. Gas & Oil public water system was notified in correspondence dated January 27, 2011, to respond in writing within 45 days of receipt of your letter, with time frames for the following requirements:

REQUIREMENT

- Sample Siting Plan – OAC Chapter 3745-81-21(A) requires public water systems to prepare a written coliform bacteria sample siting plan. A sample siting plan was also required during previous surveys.

In violation of this rule, Gas & Oil PWS still has not completed and submitted a copy of a sample siting plan. Please complete the plan and mail a completed copy to this office. The plan should be updated as information or conditions change. Please maintain the plan on site for subsequent inspections.

Per OAC 3745-81-60(D), a responsible official of the public water system must respond, in writing, within 45 days, indicating how and on what schedule the system will address the following new requirements determined as a result of the sanitary survey:

- Detail Plans – You must submit detail plans of your well and pressure tank to this office for approval by the Director. Directions for detail plan submission are enclosed for your reference. As a part of detail plan submission, a set of complete raw (prior to treatment) water analyses will need to be conducted following a

minimum eight-hour pump test. I have enclosed a list of parameters for which to test your wells and instructions for the submission of detail plans for your use. Please conduct the pump test and analyses within 45 days of receipt of this letter. Please follow up with detail plan submission within 45 days of receipt of the raw water analyses. Please note that Detail Plans, along with the review fee, must be sent to Ohio EPA NEDO, 2110 E. Aurora Rd., Twinsburg, OH 44087.

Please also be aware of these general requirements that affect all public water systems:

- Routine Monitoring – You will receive a monitoring schedule at the end of each year that will be effective for the upcoming year. The sampling requirements will include total coliform and nitrate.
 - Total Coliform Sampling – Gas & Oil is required to collect a minimum of one total coliform bacteria sample per calendar quarter and have it analyzed by an Ohio EPA certified laboratory.
 - Nitrate Sampling - Gas & Oil is required to collect and analyze a water sample for nitrate yearly between June 1 and October 31 and have it analyzed by an Ohio EPA certified laboratory.
- Annual License to Operate – You will receive, and be required to submit payment for, an annual license to operate a Public Water System at the end of each year that will be effective for the upcoming year.

RECOMMENDATION

The following deficiencies are not regulatory violations, but are actions that are recommended by this Agency for optimum operation and to reduce the potential for future violations or contamination:

- SWAP – The 1996 Amendments to the Safe Drinking Water Act require Ohio EPA to conduct source water assessments for all public water systems. The assessment of your water system will assist you in identifying the potential threats to your water supply, and help you develop protective strategies for your water supply. These reports contain checklists of protective strategies for contaminant sources identified within the report. The reports also identify the susceptibility of your sources to contamination. A SWAP report was issued to your PWS on March 28, 2005, and identified the susceptibility of your source to contamination as moderate.

We have requested that another copy be sent to you. Please review the report and complete the checklist of protective strategies. Return the checklist to this office within 45 days of receipt of the report.

GAS AND OIL
JUNE 8, 2011
PAGE 3 OF 3

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions, please contact me at (330) 963-1194.

Sincerely,



Beth Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM:dms

pc: C.O. - DDAGW/OFAS
Wayne County Health Dept.
Christina Jones, Gas & Oil, 18575 Edwards Rd., Doylestown, OH 44230
Tim Moneskey, Gas & Oil, Inc., 1256 Krumroy Rd., Akron, OH 44306