

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



June 8, 2011

RE: WAYNE COUNTY
COUNTY LINE BAR
TRANSIENT, NON-COMMUNITY PUBLIC
WATER SYSTEM
PWS ID# OH855512

CERTIFIED MAIL

Ms. Lynn Smith
County Line Bar
15580 Rittman Road
Rittman, OH 44270

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

Dear Ms. Smith:

This letter is notification that the County Line Bar public water system has not complied with requirements issued during this Agency's last survey performed on February 16, 2011, in violation of rule 3745-81-60 of the Ohio Administrative Code. County Line Bar public water system was notified in correspondence dated February 28, 2011, to respond in writing within 30 days of receipt of your letter, with timeframes for the following requirements:

REQUIREMENT(S)

- Well Cap – During the survey, we noted that your well cap is older, and in order to keep contaminants from entering your well, you need to ensure your well is kept in good condition. Your well cap did not appear to be securely fastened or able to be fastened in a manner to inhibit contaminants from entering your well. You will need to replace it with a new gasketed and vented watertight cap that meets the specifications set forth in OAC 3745-9-05(P). This regulation states:

“A well shall have a well cap or seal to prevent the entrance of water, dirt, animals, insects, or other foreign matter. The top of the casing at its finished height shall be cut so that the surface will fit flush with the well cap and provide a tight seal. The well cap or seal shall fit securely to the top of the well casing, be secured with screws or other appropriate connections, and vent to the atmosphere.”

COUNTY LINE BAR
JUNE 8, 2011
PAGE 2 OF 2

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions, please contact me at (330) 963-1194.

Sincerely,



Beth Madis
Environmental Specialist
Division of Drinking and Ground Waters

BM:ds

pc: C.O. – Ohio EPA, DDAGW/OFAS
Wayne County Health Dept.