


**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



June 7, 2011

RE: WAYNE COUNTY
GREEN MEADOWS ESTATES
COMMUNITY WATER SYSTEM
PWS #OH8505212

Mr. Art Saunders
Green Meadows Estates
5854 Cleveland Road
Wooster, OH 44691

Dear Mr. Saunders:

On May 9, 2011, this office received the April 2011 Monthly Operating Report (MOR form 5002) from Green Meadows Estates PWS. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Green Meadows Estates treats its water by chlorination (disinfection), and softening (hardness, iron, and manganese removal), you are required to conduct monitoring for chlorine residual, hardness, iron, and manganese.

Please note the following violation:

- OAC 3745-83-01(G) requires a public water system serving fewer than 250 persons that provides treatment to reduce hardness, iron, and manganese shall monitor for hardness, iron, and manganese at least monthly at each entry point into the distribution system using state certified laboratory. No hardness, iron, or manganese results were reported for the month of April 2011.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM:dms

pc: Carol Sanford, 11563 Back Massillon Rd, #35, Orrville, OH 44667
Wayne County Health Department
Ohio EPA, DDAGW-CO