

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



June 1, 2011

RE: WAYNE COUNTY  
APOSTOLIC CHRISTIAN HOME  
COMMUNITY WATER SYSTEM  
PWS ID #OH8500012

Mr. Dave Maletich, Administrator  
Apostolic Christian Home  
8329 Coal Bank Road  
Marshallville, OH 44645

Dear Mr. Maletich:

On May 9, 2011, this office received the April 2011 Monthly Operating Report (MOR form 5002) from Apostolic Christian Home PWS. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Apostolic Christian Home treats its water by softening (hardness removal) and chlorine injection (disinfection), you are required to conduct monitoring for hardness and chlorine residual.

Please note the following violation:

- OAC 3745-83-01(G) requires a public water system serving fewer than two hundred and fifty persons that provides treatment to reduce hardness shall monitor for hardness at least monthly at each entry point into the distribution system using a state certified laboratory. No hardness results were reported for the month of April 2011.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, [beth.madis@epa.state.oh.us](mailto:beth.madis@epa.state.oh.us).

Sincerely,

Beth R. Madis  
Environmental Specialist  
Division of Drinking and Ground Waters

BRM:dms

pc: Mr. Lonnie McGhee, McGhee's Technical Water Service, Inc.  
Wayne County Health Department  
Ohio EPA, DDAGW, CO