

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



June 1, 2011

RE: WAYNE COUNTY  
LITTLE CHIPPEWA ESTATES  
COMMUNITY WATER SYSTEM  
PWS #OH8501712

Melrose MHP, LLC  
4400 Melrose Drive, #301  
Wooster, OH 44691

Dear Sir or Madam:

On May 9, 2011, this office received the April 2011 Monthly Operating Report (MOR form 5002) from Little Chippewa Estates PWS. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Little Chippewa Estates treats its water by chlorination (disinfection), you are required to conduct monitoring for chlorine residual.

Please note the following violation:

- OAC Section 3745-83-01 requires all community and major non-community water systems to maintain a minimum chlorine residual of at least 0.2 mg/L free chlorine, or 1.0 mg/L combined chlorine, measured at representative points throughout the distribution system. On 16 of 31 days during the month of April 2011, chlorine residuals were reported as less than 0.2 mg/L free chlorine, or 1.0 mg/L combined chlorine.

You must investigate the cause of the low chlorine levels and ensure the chlorine levels remain at an acceptable level.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, [beth.madis@epa.state.oh.us](mailto:beth.madis@epa.state.oh.us).

Sincerely,

A handwritten signature in cursive script that reads "Beth R. Madis".

Beth R. Madis  
Environmental Specialist  
Division of Drinking and Ground Waters

BRM:dms

pc: Carol Sanford  
Wayne County Health Department  
Ohio EPA, DDAGW,CO