

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



June 1, 2011

RE: WAYNE COUNTY
BURBANK PARKE
COMMUNITY WATER SYSTEM
PWS ID #OH8563912

Ms. Regina Arborgast, Administrator
Burbank Parke
14976 Burbank Road
Burbank, OH 44645

Dear Ms. Arborgast:

On May 9, 2011, this office received the April 2011 Monthly Operating Report (MOR form 5002) from Burbank Parke PWS. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Burbank Parke treats its water by phosphate addition (sequestration) and chlorine injection (disinfection), you are required to conduct monitoring for phosphate and chlorine residual.

Please note the following violation:

- OAC 3745-83-01(G) requires a public water system that provides water treated with chlorine to monitor for free and combined chlorine at least once every day that water is available to the public at each entry point to the distribution system and a representative point in the distribution system. On the April 2011 MOR, residuals were not recorded. Please provide this office with an updated MOR showing the chlorine residuals for April 2011.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM:dms

pc: Mr. Lonnie McGhee, McGhee's Technical Water Service
Wayne County Health Department
Ohio EPA, DDAGW, CO