

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



May 2, 2011

RE: WAYNE COUNTY
MCDONALD'S RESTAURANT - WOOSTER
NON-TRANSIENT, NON-COMMUNITY
PUBLIC WATER SYSTEM
PWS ID # OH8553912
STU ID # 8559762

Ms. Teresa Dulemba
McDonald's Restaurant
2130 E. Lincoln Way
Wooster, OH 44691

Dear Ms. Dulemba:

On April 20, 2011, this office received the March 2011 Monthly Operating Report (MOR form 5002) from McDonald's Restaurant - Wooster. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since McDonald's Restaurant - Wooster treats its water by softening (hardness removal) and chlorine injection (disinfection), you are required to conduct monitoring for hardness and chlorine residual.

Please note the following violations:

1. OAC Section 3745-83-01 requires all community and major non-community water systems to maintain a minimum chlorine residual of at least 0.2 mg/L free chlorine, or 1.0 mg/L combined chlorine, measured at representative points throughout the distribution system. On 13 of 30 days during the month of March 2011, chlorine residuals were reported as less than 0.2 mg/L free chlorine, or 1.0 mg/L combined chlorine. On most of the remaining days, the chlorine levels were very high.


Please ensure that chlorine residuals are tracked on a daily basis at both the entry point and out in distribution. Also, please investigate the cause of the low and fluctuating chlorine residuals and work to resolve the issue.

2. OAC 3745-83-01(G)(8)(a) requires a public water system serving fewer than two hundred and fifty persons that provide ion exchange treatment or membrane technology to reduce hardness shall monitor for hardness at least monthly at each entry point to the distribution system using a state certified laboratory. Since you are providing water softening, a monthly hardness sample is required to be collected, analyzed, and reported on the MOR.

MCDONALD'S RESTAURANT - WOOSTER
MAY 2, 2011
PAGE 2

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,



Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Kristi Carathers, McDonald's Restaurant
Wayne County Health Department
Ohio EPA, Central Office, DDAGW