

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



February 23, 2011

RE: WAYNE COUNTY
SPRUCE TREE VILLAGE
5848 CLEVELAND RD., WOOSTER, OH
COMMUNITY WATER SYSTEM
PWS # OH8503812
STU # 8559618

Mr. Art Saunders
Asset Management Services
P.O. Box 567
Wooster, OH 44691

Dear Mr. Saunders:

On February 8, 2011, this office received the January 2011 Monthly Operating Report (MOR form 5002) from Spruce Tree Village Estates PWS. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Spruce Tree Village Estates treats its water by chlorination (disinfection) and softening (hardness removal), you are required to conduct monitoring for chlorine residual and hardness.

Please note the following violation:

- Ohio Administrative Code (OAC) 3745-83-01(G) requires a public water system serving fewer than two hundred and fifty persons that provides treatment to reduce hardness shall monitor for hardness at least monthly at each entry point into the distribution system using a state certified laboratory. No hardness results were reported for the month of January 2011.
- OAC 3745-83-01(I)(1)(c) requires a public water system to report the daily production from the PWS. The production values reported under "Production (MGD)" on your MOR do not appear likely to be actual production values, listed in MGD, since the levels are very high. I do see under the "Comments" section are what appears to be daily production values. Please begin to report the daily production, as required, on the MOR under the column entitled "Production (MGD)".

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Carol Sanford
Wayne County Health Department
Ohio EPA, Central Office, DDAGW