

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



February 2, 2011

RE: WAYNE COUNTY
OAK PARK ESTATES
COMMUNITY WATER SYSTEM
PWS ID # OH8502512
STU ID # 8559606

Ms. Kim Stratton, Property Manager
Oak Park Estates
14740 Oak Grove Dr.
Doylestown, OH 44230

Dear Ms. Stratton:

On December 5, 2010, this office received the December 2010 Monthly Operating Report (MOR form 5002) from Oak Park Estates PWS. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Oak Park Estates treats its water by softening (hardness removal) and chlorine injection (disinfection), you are required to conduct monitoring for hardness, iron, manganese, and chlorine residual.

Please note the following violation:

- Ohio Administrative Code (OAC) 3745-83-01(G) requires a public water system serving fewer than two hundred and fifty persons that provides treatment to reduce hardness shall monitor for hardness at least monthly at each entry point into the distribution system using a state certified laboratory. No hardness results were reported for the month of December 2010.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Denny White
Wayne County Health Department
Ohio EPA, Central Office, DDAGW