

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



February 2, 2011

RE: CROWN HILL MANOR  
COMMUNITY WATER SYSTEM  
PWS ID # OH8561412  
STU ID # 8561137

Mr. Arthur Shoup  
Crown Hill Manor  
9652 Akron Rd.  
Rittman, OH 44691

Dear Mr. Shoup:

On January 28, 2011, this office received the December 2010 Monthly Operating Report (MOR form 5002) from Crown Hill Manor PWS. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Crown Hill Manor treats its water by potassium permanganate injection for manganese green sand filtration (iron and manganese removal) and chlorine injection (disinfection), you are required to conduct monitoring for iron, manganese, and chlorine residual.

Please note the following violation:

- OAC 3745-83-01(G) requires a public water system that provides water treated with chlorine to monitor for free and combined chlorine at least once every day that water is available to the public at each entry point to the distribution system and a representative point in the distribution system. On the December 2010 MOR, residuals were not recorded for 4 of the 31 days. Please monitor and record residuals each day.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, [beth.madis@epa.state.oh.us](mailto:beth.madis@epa.state.oh.us).

Sincerely,

Beth R. Madis  
Environmental Specialist  
Division of Drinking and Ground Waters

BRM/ams

cc: Rick Jackson  
Wayne County Health Department  
Ohio EPA, Central Office, DDAGW