



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

February 2, 2011

RE: WAYNE COUNTY  
SPRUCE TREE VILLAGE  
5848 CLEVELAND RD., WOOSTER, OH  
COMMUNITY WATER SYSTEM  
PWS # OH8503812  
STU # 8559618

Mr. Art Saunders  
Asset Management Services  
P.O. Box 567  
Wooster, OH 44691

Dear Mr. Saunders:

On January 10, 2011, this office received the December 2010 Monthly Operating Report (MOR form 5002) from Spruce Tree Village Estates PWS. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Spruce Tree Village Estates treats its water by chlorination (disinfection) and softening (hardness removal), you are required to conduct monitoring for chlorine residual and hardness.

Please note the following violation:

- Ohio Administrative Code (OAC) 3745-83-01(G) requires a public water system serving fewer than two hundred and fifty persons that provides treatment to reduce hardness shall monitor for hardness at least monthly at each entry point into the distribution system using a state certified laboratory. No hardness results were reported for the month of December 2010.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, [beth.madis@epa.state.oh.us](mailto:beth.madis@epa.state.oh.us).

Sincerely,

Beth R. Madis  
Environmental Specialist  
Division of Drinking and Ground Waters

BRM/ams

cc: Carol Sanford  
Wayne County Health Department  
Ohio EPA, Central Office, DDAGW