

**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



February 2, 2011

RE: WAYNE COUNTY
GREEN MEADOWS ESTATES
5974 CLEVELAND RD., WOOSTER, OH
COMMUNITY WATER SYSTEM
PWS # OH8505212
STU # 8559630

Mr. Art Saunders
Asset Management Services
P.O. Box 567
Wooster, OH 44691

Dear Mr. Saunders:

On January 10, 2011, this office received the December 2010 Monthly Operating Report (MOR form 5002) from Green Meadows Estates PWS. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Green Meadows Estates treats its water by chlorination (disinfection), and softening (hardness, iron, and manganese removal), you are required to conduct monitoring for chlorine residual, hardness, iron, and manganese.

Please note the following violation:

- OAC 3745-83-01(G) requires a public water system serving fewer than two hundred and fifty persons that provides treatment to reduce hardness, iron, and manganese shall monitor for hardness, iron, and manganese at least monthly at each entry point into the distribution system using state certified laboratory. No hardness, iron, or manganese results were reported for the month of December 2010.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

A handwritten signature in cursive script that reads "Beth R. Madis".

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Carol Sanford
Wayne County Health Department
Ohio EPA, Central Office, DDAGW