

**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



February 2, 2011

RE: WAYNE COUNTY
LINCOLN TERRACE ESTATES
110 NW LEBANON RD., DALTON, OH
COMMUNITY WATER SYSTEM
PWS ID # OH8501612
STU ID # 8559600

Mr. James Moore
Moore Enterprises
4425 W. Airport Frwy #475
Irving, TX 75062

Dear Mr. Moore:

On January 28, 2011, this office received the December 2010 Monthly Operating Report (MOR form 5002) from Lincoln Terrace Estates PWS. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Lincoln Terrace Estates treats its water by chlorine injection (disinfection), you are required to conduct monitoring for chlorine residual.

Please note the following violation:

- OAC 3745-83-01(G) requires a public water system that provides water treated with chlorine to monitor for free and combined chlorine at least once every day that water is available to the public at each entry point to the distribution system and a representative point in the distribution system. On the December 2010 MOR, residuals were not recorded for 4 of the 31 days. Please monitor and record residuals each day.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Genny Mitchell, Lincoln Terrace Estates
Tony Weirich, McGhee's Technical Water Service, Inc.
Wayne County Health Department
Ohio EPA, Central Office, DDAGW