



**Environmental
Protection Agency**

Secretary, Governor
Deputy Secretary, Lt. Governor
Chief, Regional Office, Director



January 4, 2011

RE: WAYNE COUNTY
MILLBORNE MOBILE HOME COMMUNITY
240 N. MILLBORNE RD., ORRVILLE
COMMUNITY WATER SYSTEM
PWS ID # OH8502212
STU ID # 8559604

Mr. James Moore
Moore Enterprises
4425 W. Airport FRWY #475
Irving, TX 75062

Dear Mr. Moore:

On December 6, 2010, this office received the November 2010 Monthly Operating Report (MOR form 5002) from Millborne Mobile Home Community. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Millborne Mobile Home Community treats its water by chlorination (disinfection and oxidation) and greensand filtration (iron and manganese removal), you are required to conduct monitoring for chlorine residual and iron and manganese.

Please note the following violation:

At least one sample each month for iron and manganese is required to be analyzed by a certified laboratory. In accordance with Ohio Administrative Code (OAC) 3745-82-02, plant tap iron levels must remain at or below the secondary maximum contaminant level (MCL) of 0.3 milligram per liter (mg/L) at all times. Plant tap manganese levels must remain at or below the secondary MCL of 0.05 mg/L at all times.

On the November 2010 MOR, the iron and manganese levels were reported as summarized in the following table:


Sample Collection Date	Iron Results in mg/L	Manganese Results in mg/L
November 9, 2010	0.28	0.102

The manganese level may indicate that the equipment is not operating effectively and should be adjusted immediately.

MILLBORNE MOBILE HOME COMMUNITY
JANUARY 4, 2011
PAGE 2

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

A handwritten signature in cursive script that reads "Beth R Madis".

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Wayne County Health Department
Ohio EPA, Central Office, DDAGW
Tony Weirich, McGhee's Technical Water Services, Inc.