

**Environmental
Protection Agency**

Richard Cordusio, Governor
Lee Fisher, Lt. Governor
Chris Matoski, Director



January 4, 2011

RE: WAYNE COUNTY
GREEN MEADOWS ESTATES
5974 CLEVELAND RD., WOOSTER, OH
COMMUNITY WATER SYSTEM
PWS # OH8505212
STU # 8559630

Mr. Art Saunders
Asset Management Services
P.O. Box 567
Wooster, OH 44691

Dear Mr. Saunders:

On December 5, 2010, this office received the November 2010 Monthly Operating Report (MOR form 5002) from Green Meadows Estates PWS. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Green Meadows Estates treats its water by chlorination (disinfection), and softening (hardness, iron, and manganese removal), you are required to conduct monitoring for chlorine residual, hardness, iron, and manganese.

Please note the following violations:

1. Ohio Administrative Code (OAC) Section 3745-83-01 requires all community and major non-community water systems to maintain a minimum chlorine residual of at least 0.2 mg/L free chlorine, or 1.0 mg/L combined chlorine, measured at representative points throughout the distribution system. On 9 of 30 days during the month of November 2010, chlorine residuals were reported as less than 0.2 mg/L free chlorine, or 1.0 mg/L combined chlorine.
2. OAC 3745-83-01(G) requires a public water system serving fewer than two hundred and fifty persons that provides treatment to reduce hardness, iron, and manganese shall monitor for hardness, iron, and manganese at least monthly at each entry point into the distribution system using state certified laboratory. No hardness, iron, or manganese results were reported for the month of November 2010.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Carol Sanford
Wayne County Health Department
Ohio EPA, Central Office, DDAGW
Northeast District Office
2110 East Aurora Road
Twinsburg, OH 44087-1924

330 | 963 1200
330 | 487 0769 (fax)
www.epa.ohio.gov