



**Environmental
Protection Agency**

Commissioner, Governor
Deputy Commissioner, Lt. Governor
Chief of Administration, Director

January 4, 2011

RE: WAYNE COUNTY
WOOSTER ROLLING WHEELS ESTATES
7896 E. LINCOLN WAY, APPLE CREEK
COMMUNITY WATER SYSTEM
PWS ID # OH8503112
STU ID # 8559612

Jess and Gail Belton
14961 Oak Grove Dr.
Doylestown, OH 44230

Dear Mr. and Mrs. Belton:

On December 10, 2010, this office received the November 2010 Monthly Operating Report (MOR form 5002) from Wooster Rolling Wheels Estates PWS. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Wooster Rolling Wheels Estates treats its water by softening (hardness removal), chlorine injection (disinfection), and caustic soda addition, you are required to conduct monitoring for hardness, chlorine residual, and pH.

Please note the following violations:

1. Ohio Administrative Code (OAC) 3745-83-01(G) requires a public water system that provides water treated with chlorine to monitor for free and combined chlorine at least once every day that water is available to the public at each entry point to the distribution system and a representative point in the distribution system. On the November 2010 MOR, residuals were not recorded for 6 of the 30 days. Please monitor and record residuals each day.
2. OAC 3745-83-01(G)(6)(a) requires a public water system that adjusts the pH of the water supply for corrosion control pursuant to rules 3745-81-81 and 3745-81-82 of the Administrative Code shall monitor for pH once every two weeks at regular intervals at each entry point to the distribution system. Please monitor and record a pH sample every other week.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Rick Jackson
Wayne County Health Department
Ohio EPA, Central Office, DDAGW

Northeast District Office
2110 East Aurora Road
Twinsburg, OH 44087-1924

330 | 963 1200
330 | 487 0769 (fax)
www.epa.ohio.gov