



**Environmental  
Protection Agency**

Commissioner, Governor  
Deputy Commissioner, Lt. Governor  
Regional Administrator, Director

August 26, 2010

**RE: SUMMIT COUNTY  
LIFE CENTER PLUS FITNESS CENTER  
NTNC WATER SYSTEM  
PWS ID#OH7733512**

Mr. Jan Rubbins  
General Manager  
Life Center Plus Fitness Center  
5133 Darrow Road  
Hudson, OH 44236

Dear Mr. Rubbins:

This letter is notification that your water system is in violation of Chapter 3745-81-86 of the Ohio Administrative Code (OAC) for failure to comply with lead and copper tap monitoring requirements.

These regulations required that your water system collect a first draw sample from at least five appropriate sites for lead and copper analyses during the June - September 2009 monitoring period. Ohio EPA records indicate that your water system failed to conduct this required monitoring. This failure to monitor for lead and copper at consumer's taps is a violation of the aforementioned regulation and could subject your water system to enforcement action.

Please be advised that the following actions are required:

1. Collect a first draw sample from five appropriate taps for lead and copper during the June - September 2010 monitoring period. Please be reminded that you are required to sample for lead and copper during the warm months of June, July, August or September. Lead and copper monitoring reports are due October 10th of each monitoring period.
2. Issue public notification for your violation within 30 days by mail or hand delivery or by continuous posting in conspicuous places throughout the area served by the water system. An example public notice is attached for your information. A copy of the public notification, along with the enclosed verification form, must be forwarded to this office within ten days following issuance of the public notification.
3. **Consumer Notice of Tap Water Results Issuance Reminder**

The new lead and copper rule became effective July 24, 2009. Any lead monitoring conducted on or after that date require a "Consumer Notice of Tap Water Results" to be issued and a verification form be sent to the Northeast District Office. Please forward an example of a notice and completed verification along with your lead and copper report. Templates can be found on our web site at: [www.epa.ohio.gov/ddagw/reporting.aspx#Forms](http://www.epa.ohio.gov/ddagw/reporting.aspx#Forms).

4. Comply with all parts of any U.S. EPA or Ohio EPA Administrative Order.

If you have any questions, please feel free to contact me at this office at (330) 963-1227.

Sincerely,

Ursula Musselman  
Environmental Specialist  
Division of Drinking and Ground Waters

cc: DDAGW-IMS, CO; Kim Etters, DDAGW, NEDO

enclosures: Public Notice, Verification Form

8557415