



State of Ohio Environmental



Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

April 29, 2010

RE: **NOTICE OF VIOLATION**  
COLUMBIANA COUNTY  
COLUMBIANA COUNTY JAIL  
COMMUNITY PUBLIC WATER SYSTEM  
PWS ID # OH1503712

Mr. Don Harrison  
Columbiana County Commissioners  
105 Market Street  
Lisbon, OH 44432

**CERTIFIED MAIL**

Dear Mr. Harrison:

This letter is notification that the Columbiana County Jail public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Columbiana County Jail PWS as reported on Monthly Operating Report (MOR) #5002 for the months of February and March 2010. Results reported on the form indicated 13 days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer by May 28, 2010. Include with your findings a map that identifies the locations of the low residuals.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

J. Robert Henn  
Environmental Specialist  
Division of Drinking and Ground Waters

JRH/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW

