




**Environmental
Protection Agency**

_____, Governor
_____, Lt. Governor
_____, Director



October 27, 2010

RE: **NOTICE OF VIOLATION**
COLUMBIANA COUNTY
VILLAGE OF NEW WATERFORD
COMMUNITY WATER SYSTEM
PWS ID # OH1501722

Mr. Terry Coburn
United Water
47250 State Route 46
New Waterford, OH 44445

CERTIFIED MAIL

Dear Mr. Coburn:

This letter is notification that the Village of New Waterford public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Village of New Waterford PWS as reported on Monthly Operating Report (MOR) #5002 for the month of August 2010. Results reported on the form indicated three days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer within 30 days. Include with your findings a map that identifies the locations of the low residuals.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

J. Robert Henn
Environmental Specialist
Division of Drinking and Ground Waters

JRH/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW