



**Environmental
Protection Agency**

Patricia A. Quinn, Governor
Robert F. Sprague, Lt. Governor
John P. Bland, Director



October 28, 2010

**RE: NOTICE OF VIOLATION
MEDINA COUNTY
MEDINA COUNTY/SHARON-WADSWORTH
COMMUNITY WATER SYSTEM
PWS ID # OH5202003**

Mr. James Troike, P.E.
Medina County Sanitary Engineer
PO Box 542
Medina, OH 44258

CERTIFIED MAIL

Dear Mr. Troike:


This letter is notification that the Medina County/Sharon-Wadsworth public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information reported on Monthly Operating Reports (MORs) for the months of July, August and September 2010. Results reported on these forms documented three days in June, six days in July and ten days in September where the minimum free chlorine residual in the distribution system was less than 0.2 mg/l.

This violation was also issued in 2009 for the same time period. The issue of low chlorine residuals during the summer months was discussed in correspondence from the last system evaluation dated August 20, 2009. Detailed plans for a new meter vault and booster chlorination system were received on October 13, 2010 and we understand that you are continuing to work on obtaining an easement for this structure. This situation must be resolved so that adequate chlorine residual is available at all times throughout the distribution system before next summer.

If you have any questions, please contact me directly at (330) 963-1235.

Respectfully,



Leslie Otten
Environmental Specialist
Division of Drinking and Ground Waters

LO:Lds

cc: Mr. Tracy Phelps, P.E., Sup't. of Treatment
Mr. Larry Bailey, Water Supply Coordinator
Toni Buchanan, Ohio EPA, Central Office, DDAGW