



**Environmental  
Protection Agency**

\_\_\_\_\_, Governor  
\_\_\_\_\_, Lt. Governor  
\_\_\_\_\_, Director



October 27, 2010

RE: **NOTICE OF VIOLATION**  
SUMMIT COUNTY  
PEBBLE CREEK CONVALESCENT CENTER  
COMMUNITY WATER SYSTEM  
PWS ID # OH7707412

Mr. Mike Varner  
Pebble Creek Convalescent Center  
670 Jarvis Rd.  
Akron, OH 44319

**CERTIFIED MAIL**

Dear Mr. Varner:

This letter is notification that the Pebble Creek Convalescent Center public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Pebble Creek Convalescent Center PWS as reported on Monthly Operating Report (MOR) #5002 for the month of September 2010. Results reported on the form indicated five days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer within 30 days. Include with your findings a map that identifies the locations of the low residuals.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

J. Robert Henn  
Environmental Specialist  
Division of Drinking and Ground Waters

JRH/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW