



**Environmental
Protection Agency**

Director, Governor
 Lt. Governor
 Director



October 27, 2010

RE: SUMMIT COUNTY
 CITY OF CUYAHOGA FALLS
 COMMUNITY WATER SYSTEM
 PWS ID # OH7701012

Mr. David Young
 City of Cuyahoga Falls
 2310 Second Street
 Cuyahoga Falls, OH 44221

NOTICE OF VIOLATION

Dear Mr. Young:

This letter is notice that the City of Cuyahoga Falls public water system is in violation of Ohio Revised Code Section 6109.20 for failure to provide a treated water fluoride level of **0.8 to 1.3 mg/L**. The violations are noted below:

<u>DATE</u>	<u>PLANT TAP FLUORIDE LEVEL</u>
September 2, 2010	0.73 (mg/l)
September 7, 2010	0.7 (mg/l)
September 8, 2010	0.64 (mg/l)

An evaluation/investigation should be conducted to determine why the low Fluoride levels occurred and what corrective action is necessary. Please provide your findings to this writer within 30 days.

Please be advised that the City of Cuyahoga Falls public water system is not required to issue a public notice for the above mentioned violation(s).

If you should have any questions, please contact me directly at (330) 963-1248.

Sincerely,

J. Robert Henn
 Environmental Specialist
 Division of Drinking and Ground Waters

JRH/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
 Kim Etters, Ohio EPA, NEDO, DDAGW