



**Environmental
Protection Agency**

Ed Susi, Inc., Governor
Lee Fisher, Lt. Governor
Chris Leweski, Director



October 27, 2010

RE: **NOTICE OF VIOLATION**
SUMMIT COUNTY
GREENTREE PLACE #4866 & #4900
COMMUNITY WATER SYSTEM
PWS ID # OH7707712
PWS ID # OH7707912

Ms. Jean Hobbs
Greentree Place Apartments
P.O. Box 157
Green, OH 44232

CERTIFIED MAIL

Dear Ms. Hobbs:

This letter is notification that the Greentree Place #4866 & Greentree Place #4900 public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Greentree Place #4866 & Greentree Place #4900 PWS as reported on Monthly Operating Report (MOR) #5002 for the month of September 2010. Results reported on the form indicated one day and four days, respectively, where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer within 30 days. Include with your findings a map that identifies the locations of the low residuals.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

J. Robert Henn
Environmental Specialist
Division of Drinking and Ground Waters

JRH/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Stivo DiFranco, Ohio EPA, NEDO, DDAGW