



State of Ohio Environmenta



## Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

May 26, 2009

RE: **NOTICE OF VIOLATION**  
SUMMIT COUNTY  
SEASONS REHAB & CARE CENTER  
COMMUNITY PUBLIC WATER SYSTEM  
PWS ID # OH7704812

Ms. Meredith Flaherty  
Seasons Rehab & Care Center  
456 Seasons Rd.  
Stow, OH 44224

**CERTIFIED MAIL**

Dear Ms. Flaherty:

This letter is notification that the Seasons Rehab & Care Center public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Seasons Rehab & Care Center PWS as reported on Monthly Operating Report (MOR) #5002 for the month of March 2009. Results reported on the forms indicated 9 days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer by June 26, 2009. Include with your findings a map that identifies the locations of the low residuals.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully

J. Robert Henn  
Environmental Specialist  
Division of Drinking and Ground Waters

JRH/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW