



State of Ohio Environmen



## Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

May 26, 2009

RE: **NOTICE OF VIOLATION**  
SUMMIT COUNTY  
PENGUIN CONDOMINIUMS  
COMMUNITY PUBLIC WATER SYSTEM  
PWS ID # OH7709112

Mr. Gary Lemmon  
G.L. Management, Inc.  
1640 Franklin Ave., Suite 108  
Kent, OH 44240

**CERTIFIED MAIL**

Dear Mr. Lemmon:

This letter is notification that the Penguin Condominiums public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Penguin Condominiums PWS as reported on Monthly Operating Report (MOR) #5002 for the months of March and April 2009. Results reported on the forms indicated 7 days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer by June 26, 2009. Include with your findings a map that identifies the locations of the low residuals.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

J. Robert Henn  
Environmental Specialist  
Division of Drinking and Ground Waters

JRH/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Brandon Mantel, Donamarc Water Systems Co.