



State of Ohio Environmental
Northeast District



* 0 H 1 0 0 0 1 2 3 2 2 0 0 9 N O V *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 2, 2009

RE: **NOTICE OF VIOLATION**
CARROLL COUNTY
VILLAGE OF CARROLLTON
COMMUNITY WATER SYSTEM
PWS ID # OH1000012

Mr. Mike Leslie, Superintendent
80 Second Street, SW
Carrollton, OH 44615

CERTIFIED MAIL

Dear Mr. Leslie:

This letter is notification that the Village of Carrollton's public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Village of Carrollton PWS as reported on Monthly Operating Report (MOR) #5002 for January 2009. Results reported on the form indicated three days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual: January 25, January 27 and January 30, 2009.

An evaluation/investigation should be conducted to determine why the low residuals occurred and what corrective action is necessary. Please provide your findings to this writer by March 31, 2009. Include with your findings a map that identifies the locations of the low residuals.

If you have any questions, please contact me directly at (330) 963-1293.

Respectfully,

Cynthia M. Petretich
Environmental Specialist
Division of Drinking and Ground Waters

CMP/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Kim Etters, Ohio EPA, NEDO, DDAGW
Robert Fowler, Village Administrator