



State of Ohio Environmental



Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

April 22, 2009

RE: GEAUGA COUNTY  
**RICHARD'S CAMPGROUND**  
TRANSIENT WATER SYSTEM  
PWS ID: OH2845412  
STU ID: 2854410

**CERTIFIED**

Mr. Joe Workman  
P.O. Box 185  
Thompson, OH 44086

**Subject: Notice of Violation for Failure to Respond to a Significant Deficiency**

Dear Mr. Workman:

This letter is notification that Richard's Campground has not complied with requirements issued during this Agency's last survey performed on August 7, 2008 and September 12, 2008 in violation of rule 3745-81-60 of the Ohio Administrative Code. The water system was notified in correspondence dated September 25, 2008 to respond in writing no later than 45 days, with time frames for:

- Resolving pressure tank and low pressure issues
- Replacing broken pressure gauge
- Achieving positive draining around wellhead
- Providing wellhead maintenance – protection from contamination
- Using NSF-Approved Chlorine
- Replacing yard hydrants with weep holes
- Acquiring detail plan approval (if water system changes are desired)
- Performing electrical work

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions, please contact me at 330-963-1149

Sincerely,

Kathy Metropulos  
Environmental Specialist  
Division of Drinking and Ground Waters

KM:ds

cc: Geauga County Health Dept.  
Central Office, DDAGW