



State of Ohio Environmental

Northeast District



2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

April 22, 2009

RE: GEAUGA COUNTY  
**LUCIANO'S RISTORANTE**  
TRANSIENT WATER SYSTEM  
PWS ID: OH2843612  
STU ID: 2854392

**CERTIFIED**

Mr. Luciano Scalera  
Luciano's Ristorante  
8561 E Washington St.  
Chagrin Falls, OH 44022

**Subject: Notice of Violation for Failure to Respond to a Significant Deficiency**

Dear Mr. Scalera:

This letter is notification that the Luciano's Ristorante has not complied with requirements issued during this Agency's last survey performed on January 21, 2009 in violation of rule 3745-81-60 of the Ohio Administrative Code. The water system was notified in correspondence dated January 27, 2009 to respond in writing no later than 45 days, with time frames for:

- Using NSF-approved salt;
- Creating an acceptable air gap between the water softening backwash line and the floor drain;
- Checking well issues that could not be evaluated due to snow cover on day of survey;
- The ground directly adjacent to the well casing must be sloped away from the well casing;
- The casing must be undamaged, and not have holes or any other condition that would allow contaminants to enter the well;
- The well cap must be secure, tightly sealing, and not loose. There also must be a screened, down-turned vent to prevent the entrance of insects and foreign material.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions, please contact me at 330-963-1149.

Sincerely,

Kathy Metropulos  
Environmental Specialist  
Division of Drinking and Ground Waters

KM:ds

cc: Geauga County Health Dept.  
Central Office, DDAGW