



State of Ohio Environmen



Northeast Dist... * _ 0 H 2 8 6 8 7 1 2 5 1 2 2 0 0 9 N O V *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 12, 2009

RE: GEAUGA COUNTY
MANGIA, INC.
TRANSIENT WATER SYSTEM
PWS ID # OH2868712
STU ID # 2854574

CERTIFIED

Mr. Jeff Corrigan
Mangia, Inc.
P.O. Box 206
Newbury, OH 44065

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

Dear Mr. Corrigan:

This letter is notification that Mangia, Inc. has not complied with requirements issued during this Agency's last survey performed on October 20, 2008 in violation of rule 3745-81-60 of the Ohio Administrative Code. The water system was notified in correspondence dated October 31, 2008, to respond in writing no later than 45 days, with time frames for:

- Acquiring a secure, tightly sealing well cap that is properly vented
- Using NSF-approved chlorine in the water system
- Using NSF-approved salt in the water system
- Returning public notice and verification forms to Ohio EPA
- Obtaining detail plan approval (if substantial changes are made to water system)

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions, please contact me at 330-963-1149.

Sincerely,

Kathy Metropulos
Environmental Specialist
Division of Drinking and Ground Waters

KM:ds

cc: Geauga County Health Dept.
Central Office, DDAGW