



State of Ohio Environment



Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 13, 2009

RE: MEDINA COUNTY  
**VILLAGE OF LODI**  
COMMUNITY WATER SYSTEM  
PWS ID. NO. 5200412

**NOTICE OF VIOLATION**

Mr. Harold Kasten-Krause  
Utilities Superintendent  
Village of Lodi  
P.O. Box 95  
Lodi, OH 44252

Dear Mr. Kasten-Krause:

This letter is notice that the Village of Lodi public water system is in violation of Ohio Revised Code Section 6109.20 for failure to provide a treated water fluoride level of 0.8 - 1.3 mg/L. The violations are noted below:

<u>DATE</u>	<u>PLANT TAP FLUORIDE LEVEL</u>
May 2009	3 days during the month were <0.8 mg/l
June 2009	5 days during the month were <0.8 mg/l
July 2009	5 days during the month were <0.8 mg/l

In a follow-up telephone conversation with Mr. Matthey Berry, Foreman, it was reported that dry sodium fluoride may not be being added in a timely manner.

Please be advised that the Village of Lodi must take steps to ensure that the fluoride level at the plant tap is maintained between 0.8 – 1.3 mg/l as required. Continued non-compliance may result in further enforcement action.

If you should have any questions, please contact me directly at (330) 963-1235.

Sincerely,

  
Leslie Otten  
Environmental Specialist  
Division of Drinking and Ground Waters

LO:ds

pc: Toni Buchanan, DDAGW, CO  
Kim Ethers, DDAGW, NEDO