



State of Ohio Environmental

Northeast District



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 9, 2009

RE: WAYNE COUNTY
TOWN & COUNTRY CAMPGROUND
TRANSIENT WATER SYSTEM
PWS ID # OH8555312
STU 1 ID # 8559769; STU 2 ID # 8560960

Mr. Rick Witucki
Witucki, LLC
Town & Country Camp Resort
7555 Shilling Rd.
West Salem, OH 44287

CERTIFIED MAIL

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

Dear Mr. Witucki:

This letter is notification that the Town & Country Camp public water system has not complied with requirements issued during this Agency's last survey performed on June 17, 2009, in violation of rule 3745-81-60 of the Ohio Administrative Code. Town & Country Camp public water system was notified in correspondence dated July 16, 2009, to respond in writing within 45 days of receipt of your letter, with time frames for the following requirements:

REQUIREMENT(S):

The following required items were noted in the last inspection report dated November 9, 2005 as being deficient. The following is a summary of the requirements and notation as to whether they have or have not been adequately addressed.

- Detail Plans - OAC Chapter 3745-91 requires submission and approval of detail plans prior to the construction or installation of a PWS or for any substantial change to the PWS. Detail plans have never been approved for this PWS. Detail plans were also requested during previous surveys due to the addition of the softener. However, during this survey, it appeared as if the softener is solely serving the line that serves house. If this is the case, detail plans will not be required.

A previously-submitted drawing shows that the softener serves the home, as well as the laundry and bath house. If this is the case, then the softener would be a part of the public water system and require plan approval.

Please explain the water system lay-out. If the softener serves more than the home, detail plans will need to be submitted for the well and water treatment equipment. Enclosed are instructions for detail plan submission. Please submit detail plans and water supply data sheet (on the reverse side of the detail plans

TOWN & COUNTRY CAMPGROUND
OCTOBER 9, 2009
PAGE 2

instructions), along with the appropriate review fee, to this office within 45 days of receipt of this letter.

RECOMMENDATION(S):

The following deficiencies are not regulatory violations, but are actions that are recommended by this Agency for optimum operation and to reduce the potential for future violations or contamination:

- SWAP – The 1996 Amendments to the Safe Drinking Water Act require Ohio EPA to conduct source water assessments for all public water systems. The assessment of your water system will assist you in identifying the potential threats to your water supply, and help you develop protective strategies for your water supply. These reports contain checklists of protective strategies for contaminant sources identified within the report. The report also identifies the susceptibility of your source to contamination. A SWAP report was issued to the Camp on March 28, 2005 and identified the susceptibility of your source to contamination as Low.

Please review your report and complete the checklists of protective strategies. Return the checklist to this office within 45 days of this letter date. Specific questions that you may have about the SWAP report can be answered by contacting Conni McCambridge at (330) 963-1200.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions, please contact me at (330) 963-1194.

Sincerely,



Beth Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Ohio EPA, Central Office, DDAGW / OFAS
Wayne County Health Department