



State of Ohio Environment



Northeast District Office \* 9 H 8 5 6 2 5 1 2 6 2 9 2 0 0 9 N O V \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 29, 2009

RE: HERITAGE GREEN CONDOMINIUMS - KIDRON  
COMMUNITY WATER SYSTEM  
PWS ID # OH8562512  
STU ID # 8561747

Mr. Roger Geiser  
Heritage Green Condominium Association  
106 Heritage Green Lane  
Dalton, OH 44618

Dear Mr. Geiser:

On June 9, 2009, this office received the May 2009 Monthly Operating Report (MOR form 5002) from Heritage Green Condominiums - Kidron. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Heritage Green Condominiums - Kidron treats its water by potassium permanganate injection for manganese green sand filtration (iron and manganese removal and chlorine injection (disinfection), you are required to conduct monitoring for iron, manganese, and chlorine residual.

Please note the following violation:

At least one sample each month for iron and manganese is required to be analyzed by a certified laboratory. In accordance with Ohio Administrative Code (OAC) 3745-82-02, plant tap iron levels must remain at or below the secondary maximum contaminant level (MCL) of 0.3 milligram per liter (mg/L) at all times. Plant tap manganese levels must remain at or below the secondary MCL of 0.05 mg/L at all times.

On the May 2009 MOR, the iron and manganese levels were reported as summarized in the following table:

Sample Collection Date	Iron Results in mg/L	Manganese Results in mg/L
May 14, 2009	0.08	0.757


The manganese level may indicate that the equipment is not operating effectively and should be adjusted immediately.

As we understand, your operator has been working to fix the programming on the greensand filter system in order to solve this problem. Please keep this office informed of your progress.

HERITAGE GREEN CONDOMINIUMS - KIDRON  
JUNE 29, 2009  
PAGE 2

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, [beth.madis@epa.state.oh.us](mailto:beth.madis@epa.state.oh.us).

Sincerely,



Beth R. Madis  
Environmental Specialist  
Division of Drinking and Ground Waters

BRM/ams

cc: Wayne County Health Department  
Dave Evans, Ohio EPA, Central Office, DDAGW  
Rick Jackson