



State of Ohio Environmental



Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 22, 2009

RE: WAYNE COUNTY  
GLENRIDGE MHP  
COMMUNITY WATER SYSTEM  
PWS ID # OH8501012  
STU ID # 8559598

Mr. Tom Funk  
Touchdown Properties, Ltd.  
4805 Munson St. NW  
Canton, Ohio 44718

**CERTIFIED MAIL**

Dear Mr. Funk:

On January 9, 2009, this office received the December 2008 Monthly Operating Report (MOR form 5002) from Glenridge Mobile Home Park. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Glenridge treats its water by potassium permanganate injection for manganese green sand filtration (iron and manganese removal), ion exchange softening (hardness removal), and chlorine (disinfection) injection, you are required to conduct monitoring for iron, manganese, hardness, and chlorine residual.

Please note the following violation:

At least one sample each month for iron and manganese is required to be analyzed by a certified laboratory. In accordance with Ohio Administrative Code (OAC) 3745-82-02, plant tap iron levels must remain at or below the secondary maximum contaminant level (MCL) of 0.3 milligram per liter (mg/L) at all times. Plant tap manganese levels must remain at or below the secondary MCL of 0.05 mg/L at all times.

On the December 2008 MOR, the iron and manganese levels were reported as summarized in the following table:


Sample Collection Date	Iron Results in mg/L	Manganese Results in mg/L
December 23, 2008	0.08	0.088

The manganese level may indicate that the equipment is not operating effectively and should be adjusted immediately.

GLENRIDGE MHP  
JANUARY 22, 2009  
PAGE 2

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, [beth.madis@epa.state.oh.us](mailto:beth.madis@epa.state.oh.us).

Sincerely,

A handwritten signature in cursive script that reads "Beth R. Madis".

Beth R. Madis  
Environmental Specialist  
Division of Drinking and Ground Waters

BRM/ams

cc: Wayne County Health Department  
Dave Evans, Ohio EPA, Central Office, DDAGW  
Rick Jackson