




State of Ohio Environmental

Northeast District Office



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 8, 2008

RE: GEauga COUNTY
TANGLEWOOD LAKE WATER COMPANY
COMMUNITY WATER SYSTEM
PWS ID # OH2802512
STU ID NO. 2854286

Mr. Robert Ettinger
Tanglewood Water Company
17400 Haskins Rd
Chagrin Falls, OH 44023

NOTICE OF VIOLATION

Dear Mr. Ettinger:

This letter is notice that the Tanglewood Water Company public water system is in violation of Ohio Revised Code Section 6109.20 for failure to provide a treated water fluoride level of 0.8 to 1.3 mg/L. The violations are noted below:

<u>DATE</u>	<u>PLANT TAP FLUORIDE LEVEL</u>
June 14, 2008	0.64 (mg/l)
June 13, 2008	0.60 (mg/l)
June 11, 2008	0.56 (mg/l)
June 9, 2008	0.67 (mg/l)
June 7, 2008	0.63 (mg/l)
June 6, 2008	0.59 (mg/l)
June 5, 2008	0.68 (mg/l)
May 31, 2008	0.74 (mg/l)
May 30, 2008	0.61 (mg/l)
May 29, 2008	0.59 (mg/l)
May 28, 2008	0.63 (mg/l)
May 27, 2008	0.66 (mg/l)
May 26, 2008	0.70 (mg/l)

Previous violations were discussed with you in a telephone conversation on May 5, 2008. In a follow-up telephone conversation with you on July 1, 2008, it was reported that the fluoride feeder had malfunctioned and that repairs have been made.

Please be advised that the Tanglewood Water Company public water system is not required to issue a public notice for the above mentioned violation.

If you should have any questions, please contact me directly at (330) 963-1282.

Sincerely,

Donn Meehl, Environmental Specialist
Division of Drinking and Ground Waters

DBM/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Kim Eppers, Ohio EPA, NEDO, DDAGW