



State of Ohio Environment



Northeast District Office

* OH 15025121242008 NOV *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 4, 2008

RE: **NOTICE OF VIOLATION**
COLUMBIANA COUNTY
TOMAHAWK UTILITIES
COMMUNITY PUBLIC WATER SYSTEM
PWS ID # OH1502512

Mr. Jon Robertson
P.O. Box 566
Malvern, OH 44644

CERTIFIED MAIL

Dear Mr. Robertson:

This letter is notification that the Tomahawk Utilities public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Tomahawk Utilities PWS as reported on Monthly Operating Report (MOR) #5002 for the month of October 2008. Results reported on the form indicated two days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer by January 16, 2009. Include with your findings a map that identifies the locations of the low residuals.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

J. Robert Henn
Environmental Specialist
Division of Drinking and Ground Waters

JRH/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW