



State of Ohio Environmen  
Northeast Dist

OH8541112

LIONS CLUB COMMUNITY PARK

11/17/2008



\* 0 H 8 5 4 1 1 1 2 1 1 1 7 2 0 8 N O V \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

November 17, 2008

RE: WAYNE COUNTY  
LION'S CLUB COMMUNITY PARK  
TRANSIENT, NON-COMMUNITY WATER SYSTEM  
PWS ID # OH8541112  
STU ID # 8559700

Mr. Steve Chio  
Nu-Way Construction  
9816 Ashland Rd.  
Wooster, OH 44691

**CERTIFIED MAIL**

**Subject: Notice of Violation for Failure to Respond to a Significant Deficiency**

Dear Mr. Chio:

This letter is notification that the Lions Club Park public water system has not complied with requirements issued during this Agency's last survey performed on September 17 2008, in violation of rule 3745-81-60 of the Ohio Administrative Code. Lions Club Park public water system was notified in correspondence dated September 25, 2008, to respond in writing within 45 days of receipt of your letter, with time frames for the following requirements:

**REQUIREMENT(S)**

- Sample Siting Plan - OAC Chapter 3745-81-21(A) requires public water systems to prepare a written coliform bacteria sample siting plan. Lions Club Park is in violation of this rule because we do not have a sample siting plan on file for the Lions Club Park. A sample siting plan was requested during previous surveys, as well. A template was enclosed in the September 2008 survey letter.
- Public Notification - Our records indicate that Lions Club failed to post public notices for several violations incurred between 2005 and the present. Failing to post a notice is a violation of OAC 3745-81-32, which states "the owner or operator of a public water system which fails to perform the monitoring established by this chapter, or fails to comply with a testing procedure required by this chapter, or is granted a variance or exemption pursuant to this chapter, shall notify persons served by the public water."

In order to correct the violations, you must post public notices (**enclosed in the September 2008 survey letter**) for the monitoring violations. The notices must be posted for a minimum of ten days. Within 45 days, please send a copy of the notices that you posted, along with the completed verification forms (back side of or stapled to the public notice), to this office.

LION'S CLUB COMMUNITY PARK  
NOVEMBER 17, 2008  
PAGE 2

Please note that an additional violation was incurred for July through September 2008. A notice of violation with a separate public notice (PN) was mailed to you on October 27, 2008. This PN will also need to be posted.

We also asked you to consider the following recommendation(s):

**RECOMMENDATION(S)**

- Raw Water Tap – We recommend that a sample tap be installed upstream of the pressure tank so that a raw water sample representative of the well can be obtained. If a routine sample result should be reported as total coliform positive, and some or all of the required repeat sample results are also positive, this raw water sample will assist in determining if the bacteria is coming from the well. In addition, the new Groundwater Rule, which will affect most PWSs and will become effective December 1, 2009, will require that when a total coliform positive result is received from the distribution system, a sample must be collected from the well. This sample tap should be located before the pressure tank, at a location that is easily accessible and where the sample bottle can easily be filled up. The tap should be smooth-nosed (not the type used for a hose) and produce a smooth, pencil-thin flow of reasonable velocity.

**The water system must respond in writing within 15 days from the date of this letter with the required information.** Failure to comply may result in further enforcement action.

If you have any questions, please contact me at (330) 963-1194.

Sincerely,



Beth Madis  
Environmental Specialist  
Division of Drinking and Ground Waters

BRM/ams

Enclosures

cc: Ohio EPA, Central Office, DDAGW / OFAS  
Wayne County Health Department