



State of Ohio Environment

Northeast Distr.



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 2, 2008

RE: WAYNE COUNTY
GLENRIDGE MHP
COMMUNITY WATER SYSTEM
PWS ID #OH8501012
STU ID #8559598

Mr. Tom Funk
Touchdown Properties, Ltd.
4805 Munson St. NW
Canton, Ohio 44718

CERTIFIED MAIL

Dear Mr. Funk:

On November 7, 2008, this office received the October 2008 Monthly Operating Report (MOR form 5002) from Glenridge Mobile Home Park. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Glenridge treats its water by potassium permanganate injection for manganese green sand filtration (iron and manganese removal), ion exchange softening (hardness removal), and chlorine (disinfection) injection, you are required to conduct monitoring for iron, manganese, hardness, and chlorine residual.

Please note the following violation:

At least one sample each month for iron and manganese is required to be analyzed by a certified laboratory. In accordance with Ohio Administrative Code (OAC) 3745-82-02, plant tap iron levels must remain at or below the secondary maximum contaminant level (MCL) of 0.3 milligram per liter (mg/L) at all times. Plant tap manganese levels must remain at or below the secondary MCL of 0.05 mg/L at all times.

On the October 2008 MOR, the iron and manganese levels were reported as summarized in the following table:

Sample Collection Date	Iron Results in mg/L	Manganese Results in mg/L
October 23, 2008	0.08	0.141

GLENRIDGE MHP
DECEMBER 2, 2008
PAGE 2

The manganese level may indicate that the equipment is not operating effectively and should be adjusted immediately.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

A handwritten signature in cursive script that reads "Beth R. Madis".

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Wayne County Health Department
Dave Evans, Ohio EPA, Central Office, DDAGW
Rick Jackson