



State of Ohio Environmental
Northeast District



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 31, 2008

RE: CARROLL COUNTY
VILLAGE of MALVERN WATER
COMMUNITY WATER SYSTEM
PWS ID. NO. 1000112
STU ID. NO. 1053068

Mr. James Bates
Water Plant Superintendent & Village Administrator
Village of Malvern, Water Plant
410 North Carrollton Road
P.O. Box 844
Malvern, OH 44644

NOTICE of VIOLATION

Dear Superintendent Bates:

This office has reviewed the monthly operating reports for November 2008. The results indicate that on one occasion, an exceedance of the secondary Maximum Contaminant Level (MCL) for manganese occurred. Details of this exceedance included:

<u>Date</u>	<u>Contaminant</u>	<u>Level milligrams/Liter (mg/L)</u>
November 10, 2008	Manganese	0.057

The Ohio Administrative Code (OAC) Rule 3745-82-02 has set the secondary MCL for manganese at 0.05 mg/L. Be advised that the listed result is above the secondary MCL for manganese. This office is requesting you provide an explanation of why this exceedance occurred and the corrective action(s) you are taking to avoid this exceedance in the future. Submit your response to this office within thirty days of the date of this letter.

Sincerely,

Cynthia M. Petretich
Environmental Specialist
Division of Drinking and Ground Waters

CMP:dms

pc: Dave Evans, DDAGW, CO
Kim Eters, DDAGW, NEDO
Carroll County Health Department
Dee Dee Wise, Water Plant Administrator

ec: Stivo DiFranco, Supervisor, DDAGW, NEDO