



State of Ohio Environmental



Northeast District *OH100001212312008NOV*

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 31, 2008

RE: CARROLL COUNTY
VILLAGE of CARROLLTON
COMMUNITY WATER SYSTEM
PWS ID. NO. oh1000012

Mr. Mike Leslie, Superintendent
80 Second Street, SW
Carrollton, OH 44615

NOTICE of VIOLATION

Dear Superintendent Leslie:

This letter is notice that the Village of Carrollton's public water system is in violation of Ohio Revised Code Section 6109.20 for failure to provide a treated water fluoride level of 0.8 to 1.3 mg/L. The violations are noted below:

<u>Date</u>	<u>PLANT TAP FLUORIDE LEVEL (MG/L)</u>
November 7, 2008	0.4
November 8, 2008	0.6
November 9, 2008	0.4
November 10, 2008	0.4

In a follow-up telephone conversation with you on December 31, 2008, it was reported that the fluoride feeder had failed and that repairs have been made.

Please be advised that the Village of Carrollton's public water system is not required to issue a public notice for the above mentioned violations.

If you should have any questions, please contact me directly at (330) 963-1293.

Sincerely,

Cynthia M. Petretich
Environmental Specialist
Division of Drinking and Ground Waters

CMP:dms

pc: Toni Buchanan, DDAGW, CO
Kim Eters, DDAGW, NEDO
Mr. Robert Fowler, Administrator