




State of Ohio Environmental

Northeast District



2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 5, 2008

RE: LORAIN COUNTY  
CITY OF AVON  
PWS ID # OH4700203  
POTENTIAL MONITORING AND  
REPORTING VIOLATIONS

Mr. Edward McCallie  
City of Avon Water Department  
35030 Detroit Road  
Avon, Ohio 44011

Dear Mr. McCallie:

We have reviewed the June monthly operating reports (MOR) for the City of Avon public water system. Based upon our review, there is a possible monitoring and reporting violation and a long-standing MOR submittal inadequacy that must be addressed as soon as possible. These issues are identified below.

**Plant-Distribution MOR (green report)**

Ohio Administrative Code 3745-83-01 (G) requires community public water systems monitor for free chlorine and combined chlorine residual on a daily basis. Free and combined chlorine was not reported for the entire month of June, 2008. Please verify and correct this MOR as soon as possible. Failure to monitor and accurately report free and combined chlorine on a daily basis in the future will constitute a violation of OAC 3745-83-01 (G).

**Drinking Water Distribution Report (white report)**

This report has been requested to be submitted for quite some time. The last report on file in this office was for the November, 2004 monitoring period. Please begin completing and submitting this report in the future. A blank form and instructions are enclosed.

We have made a copy of the Plant-Distribution MOR submitted for the month of June, 2008. The original is being returned to you for editing (if necessary) and resubmittal. Resubmittal must be done as soon as possible, no later than August 13, 2008. Failure to meet this deadline will result in a monitoring and reporting violation subject to public notice requirements under OAC 3745-81-32. If you should have any questions, please contact me at (330) 963-1277.

Sincerely,

Scott D. Moegling  
Environmental Specialist 3  
Division of Drinking and Ground Waters

SDM/ams

Enclosures: June, 2008 monthly operating report  
Distribution Report MOR and instructions

cc: Michael Scott, Ohio EPA, NEDO, NEDO