



State of Ohio Environmental

Northeast District



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 1, 2008

RE: LORAIN COUNTY
CITY OF AVON LAKE
COMMUNITY WATER SYSTEM
PWS ID: 4700311
STU ID: 4755816

Mr. John Kniepper
Chief Utilities Executive
City of Avon Lake
Water & Sewer Administrative Office
201 Miller Road
Avon Lake, OH 44012

NOTICE OF VIOLATION

Dear Mr. Kniepper:

This letter is notice that the Avon Lake public water system is in violation of Ohio Revised Code Section 6109.20 for failure to provide a treated water fluoride level of 0.8 to 1.3 mg/L. The violations are noted below:

DATES

12/12/07 – 12/31/07

PLANT TAP FLOURIDE LEVELS

0.12 –0.54

In telephone conversations with Ms. Elizabeth Darnell, Class IV Operator, it was reported that the fluoride feeder had broken and that a part was on order. When the part was received, Ms. Darnell notified this office the necessary repairs had been made.

Please be advised that the Avon Lake public water system is not required to issue a public notice for the above mentioned violations.

If you have any questions, please contact me at (330) 963-1182.

Sincerely,

Michael W. Scott
Environmental Specialist 2
Division of Drinking and Ground Waters

MWS:dms

pc: Ms. Elizabeth Darnell, Water Plant Superintendent
Mr. Rick Eberle, Chief of Utility Operations
Nancy Glenny, DDAGW, NEDO
Toni Buchanan, DDAGW, CO