



State of Ohio Environmental

Northeast District Office



2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 2, 2008

RE: SUMMIT COUNTY  
REX HILL MOBILE ESTATES  
COMMUNITY WATER SYSTEM  
PWS ID # OH7703812  
STU ID # 7758626

Mrs. Gail Belton  
14961 Oak Grove Dr.  
Doylestown, OH 44230

Dear Mrs. Belton:

Water samples collected weekly have been analyzed and evaluated for iron and manganese. The iron or manganese results exceed the secondary maximum contaminant level (SMCL) for iron or manganese. Rule 3745-82-02 of the Ohio Administrative Code (OAC) has set the SMCL for iron at 0.03 mg/L and manganese at 0.05 mg/L.

The following table identifies those dates where the iron or manganese levels were over the SMCL for the months of March and April 2008:

DATE	IRON (SMCL OF 0.3 mg/L)	MANGANESE (SMCL of 0.05 mg/L)
3/13/2008	0.433	
3/27/2008	1.47	
4/24/2008	2.06	0.09

Please investigate the cause of the iron and/or manganese spikes. Please send documentation back to this writer within 45 days from receipt of this letter indicating what steps have been taken to ensure that iron and/or manganese level(s) are below the SMCL.

Please contact me at (330) 963-1248, if you have any questions.

Sincerely,

J. Robert Henn, Environmental Specialist  
Division of Drinking and Ground Waters

JRH/ams