

OhioE
State of Ohio Environmental
Northeast District



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 11, 2008

RE: SUMMIT COUNTY
REX HILL MOBILE ESTATES
COMMUNITY WATER SYSTEM
PWS ID # OH7703812
STU ID # 7758626

Mrs. Gail Belton
14961 Oak Grove Dr.
Doylestown, OH 44230

Dear Mrs. Belton:

Water samples collected weekly have been analyzed and evaluated for iron and manganese. The iron or manganese results exceed the secondary maximum contaminant level (SMCL) for iron or manganese. Rule 3745-82-02 of the Ohio Administrative Code (OAC) has set the SMCL for iron at 0.03 mg/L and manganese at 0.05 mg/L.

The following table identifies those dates where the iron or manganese levels were over the SMCL for the month of February 2008:

| DATE | IRON (SMCL OF 0.3 mg/L) | MANGANESE (SMCL of 0.05 mg/L) |
|------------|----------------------------|----------------------------------|
| 02/14/2008 | 4.62 | |
| 02/21/2008 | 0.519 | |

Please investigate the cause of the iron and/or manganese spikes. Please send documentation back to this writer within 45 days from receipt of this letter indicating what steps have been taken to ensure that iron and/or manganese level(s) are below the SMCL.

Please contact me at (330) 963-1248, if you have any questions.

Sincerely,

J. Robert Henn, Environmental Specialist
Division of Drinking and Ground Waters

JRH/ams