



State of Ohio Environmer  
Northeast Dis



\* 0 H 8 5 0 0 1 1 2 2 0 0 8 N O V \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 2, 2008

RE: WAYNE COUNTY  
VILLAGE OF APPLE CREEK  
COMMUNITY WATER SYSTEM  
PWS ID # OH8500112  
STU ID # 8559590

Mayor Alan Miller  
Village of Apple Creek  
P.O. Box 208  
Apple Creek, OH 44606

Dear Mayor Miller:

Monthly Operating Reports (MORs) are provided as a means to relay compliance information about the operation of the water treatment plant. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Apple Creek treats its water by potassium permanganate injection for manganese green sand filtration (iron and manganese removal) and chlorine injection (disinfection), you are required to conduct monitoring for iron, manganese, and chlorine residual.

Please note the following violation:

In accordance with Ohio Administrative Code (OAC) 3745-83-01(1)(2), MORs must be submitted to this office no later than the tenth of the month following the month for which the report was prepared.

We do not have the microbiological MORs for the months of October and November 2007.

We do not have the plant-distribution MORs for the months of October and November 2007.

Please submit copies of these forms within 10 days of this letter date. If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

Beth R. Madis  
Environmental Specialist  
Division of Drinking and Ground Waters

BRM/ams

cc: Wayne County Health Department  
Dave Evans, Ohio EPA, Central Office, DDAGW  
Randy Danford, Village of Apple Creek