



State of Ohio Environmental



## Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 2, 2008

RE: WAYNE COUNTY  
GLENRIDGE MHP  
COMMUNITY WATER SYSTEM  
PWS ID # OH8501012  
STU ID # 8559598

Mr. Tom Funk  
Touchdown Properties, Ltd.  
4805 Munson St. NW  
Canton, Ohio 44718

Dear Mr. Funk:

Monthly Operating Reports (MORs) are provided as a means to relay compliance information about the operation of the water treatment plant. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Glenridge MHP treats its water by potassium permanganate injection for manganese green sand filtration (iron and manganese removal), and chlorine (disinfection) injection, you are required to conduct monitoring for iron, manganese, and chlorine residual.

Please note the following violation:

In accordance with Ohio Administrative Code (OAC) 3745-83-01(1)(2), MORs must be submitted to this office no later than the tenth of the month following the month for which the report was prepared.

We do not have the plant-distribution MOR for the month of November 2007.

Please submit copies of these forms within 10 days of this letter date. If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,

Beth R. Madis  
Environmental Specialist  
Division of Drinking and Ground Waters

BRM/ams

cc: Wayne County Health Department  
Dave Evans, Ohio EPA, Central Office, DDAGW