



State of Ohio Environmental
Northeast District

OH8501012

GLENRIDGE MOBILE HOME PARK

6/30/2008



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 30, 2008

RE: WAYNE COUNTY
GLENRIDGE MHP
COMMUNITY WATER SYSTEM
PWS ID #OH8501012
STU ID #8559598

Mr. Tom Funk
Touchdown Properties, Ltd.
4805 Munson St. NW
Canton, Ohio 44718

Dear Mr. Funk:

Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Glenridge treats its water by potassium permanganate injection for manganese green sand filtration (iron and manganese removal), ion exchange softening (hardness removal), and chlorine (disinfection) injection, you are required to conduct monitoring for iron, manganese, hardness, and chlorine residual.

Please note the following violation:

- A Monthly Operating Report (MOR form 5002) for the month of May 2008 was not received from Glenridge Mobile Home Park. According to Ohio Administrative Code 3745-83-01(I)(2), MORs "shall be signed by the operator in responsible charge designated in accordance with rule 3745-7-02 of the Administrative Code and submitted to the district office no later than the tenth of the month following the month for which the report was prepared." Therefore, the MOR for May 2008 was due to this office by June 10, 2008. Please submit the May 2008 MOR to this office within 14 days of receipt of this letter.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, beth.madis@epa.state.oh.us.

Sincerely,


Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Wayne County Health Department
Dave Evans, Ohio EPA, Central Office, DDAGW
Rick Jackson