



State of Ohio Environmental

Northeast District



* 0 H R 5 5 4 1 1 2 5 1 4 2 0 0 8 N O V *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 14, 2008

RE: WAYNE COUNTY
WAYNE LANES
TRANSIENT WATER SYSTEM
PWS ID #8554112
STU ID #8559763

Mr. Ray Jeffries
Wayne Lanes
1983 E. Lincoln Way
Wooster, OH 44691

CERTIFIED MAIL

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

Dear Mr. Jeffries:

This letter is notification that the Wayne Lanes PWS has not complied with requirements issued during this Agency's last survey performed on October 24, 2007, in violation of rule 3745-81-60 of the Ohio Administrative Code. Wayne Lanes was notified in correspondence dated December 7, 2007, to respond in writing no later than 45 days, with time frames for the several requirements. It appears that all required issues have been adequately addressed except for the following:

- Chlorine Testing - For systems that chlorinate, we require that chlorination practices adhere to Ohio Administrative Code requirements and operational practices. Operational sampling for chlorine residual in your distribution system is conducted to track the available chlorine that remains for continued disinfection. We, therefore, require that Wayne Lanes maintain a minimum chlorine residual of at least 0.2 milligram per liter (mg/L) free chlorine measured at representative points throughout the distribution system. By sampling and recording the residual on a daily basis, you can track the operation of your chlorination system.

During the previous survey, no chlorine residual was detected. During this survey, the chlorine residual was measured and found to contain 1.90 mg/L free chlorine, which is acceptable, but can be too high. The monitoring and recording of the chlorine residual has not been done on a consistent basis and should be monitored and recorded in a log on a daily basis. To track the chlorine residual, you will need a DPD type test kit for drinking water monitoring. Please purchase a digital chlorine test kit so that you can monitor your chlorine residual. Once a test kit has been purchased, please contact me if you need assistance with its operation.

WAYNE LANES
MAY 14, 2008
PAGE 2

A chlorine test kit is still not available at Wayne Lanes and monitoring and recording has not been conducted. **(Please note that we have been told that a test kit would be acquired. Please verify whether this happened and how often and where the chlorine residuals are being recorded.)**

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions, please contact me at (330) 963-1194.

Sincerely,



Beth Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

cc: Ohio EPA, Central Office, DDAGW / OFAS
Wayne County Health Department